

# RESOLUTION 1693

## A RESOLUTION OF THE CITY OF NORTH BEND, WASHINGTON, AUTHORIZING PURCHASE OF A REPLACEMENT ROTATING ASSEMBLY FOR THE CENTRIFUGE AT THE WASTEWATER TREATMENT PLANT

**WHEREAS**, the City installed a Centrisys centrifuge for dewatering waste activated sludge in 2004; and

**WHEREAS**, the centrifuge is critical to the solids handling process at the wastewater treatment plant; and

**WHEREAS**, the centrifuge has been experiencing problems requiring major repair of the rotating assembly which would require up to 5 weeks of down-time; and

**WHEREAS**, the solids level in the wastewater treatment plant would reach critical levels making adequate treatment nearly impossible with 5 weeks of down-time; and

**WHEREAS**, staff has determine the most prudent course of action which would result in minimum impact to WWTP operations would be to purchase a replacement rotating assembly rather than repair the existing assembly; and

**WHEREAS**, Centrisys is the only manufacturer of a replacement rotating assembly;

**NOW, THEREFORE, THE CITY COUNCIL OF THE CITY OF NORTH BEND, WASHINGTON, DOES HEREBY RESOLVE AS FOLLOWS:**

**Section 1.** Centrisys is accepted as the sole source supplier of the replacement parts needed.

**Section 2.** Staff is authorized to purchase the rotating assembly from Centrisys in the amount of \$138,000 plus applicable taxes and freight charges.

**PASSED BY THE CITY COUNCIL OF THE CITY OF NORTH BEND, WASHINGTON,  
AT A REGULAR MEETING THEREOF, THIS 22<sup>ND</sup> DAY OF SEPTEMBER, 2015.**

**CITY OF NORTH BEND:**

**APPROVED AS TO FORM:**

---

**Kenneth G. Hearing, Mayor**

---

**Michael R. Kenyon, City Attorney**

**ATTEST/AUTHENTICATED:**

Effective: September 22, 2015

Posted: September 23, 2015

---

**Susie Oppedal, City Clerk**